



# Certificate of Compliance

Certificate: 1417813

Master Contract: 219048

Project: 2764020

Date Issued: September 22, 2014

Issued to: **RangeRack Inc.**  
100-C Hymus Blvd  
Pointe-Claire, QC H9R 1E4  
Canada  
Attention: Robb Mackinnon

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Kim Nguyen*

Issued by: Kim Nguyen, P. Eng.

## PRODUCTS

**CLASS 4681 01** - WIREWAYS AND BUSWAYS - Cabletroughs

Metal cable tray systems, consisting of straight section of cable tray and fittings:

Cat No	Material	Type	Rated Load (kg/m)	Load Class	Support Span (m)
BT*-10 series	Aluminum	Ladder	37	A	3.0
BT*-8 series	Aluminum	Ladder	37	A	2.4
BT*-5 series	Aluminum	Ladder	37	A	1.5
BW4-10 series	Aluminum	Ladder	97	C	3.0
BZ4-10 series	Aluminum	Ladder	299	E	3.0
BZ6-10 series	Aluminum	Ladder	299	E	3.0
BY4-20 series	Aluminum	Ladder	67	D	6.0
BY6-20 series	Aluminum	Ladder	67	D	6.0

Notes:



**Certificate:** 1417813

**Master Contract:** 219048

**Project:** 2764020

**Date Issued:** September 22, 2014

- \*BT series only have 1-5/8 inch deep
- Suffix numbers are added to the above series in the catalogue numbering to denote:
  - Width (6 = 6 inches, 9 = 9 inches etc), and
  - Rung spacing (6 = 6 inches, 9 = 9 inches etc)

Example: BW4-10-36-12 = A 4 inch deep x 10 feet long x 36 inch wide x 12 inch rung spacing cable tray.

**CLASS 4681 81 – WIREWAYS AND BUSWAYS – Cabletroughs – Certified to US Standard**

Metal cable tray systems, consisting of straight section of cable tray and fittings:

<b>Cat No</b>	<b>Material</b>	<b>Type</b>	<b>Rated Load (kg/m)</b>	<b>Load Class</b>	<b>Support Span (m)</b>
BT*-10 series	Aluminum	Ladder	37	A	3.0
BT*-8 series	Aluminum	Ladder	37	A	2.4
BT*-5 series	Aluminum	Ladder	37	A	1.5
BW4-10 series	Aluminum	Ladder	97	C	3.0

Notes:

- \*BT series only have 1-5/8 inch deep
- Suffix numbers are added to the above series in the catalogue numbering to denote:
  - Width (6 = 6 inches, 9 = 9 inches etc), and
  - Rung spacing (6 = 6 inches, 9 = 9 inches etc)

Example: BW4-10-36-12 = A 4 inch deep x 10 feet long x 36 inch wide x 12 inch rung spacing cable tray.

**APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 126.1 - Metal Cable Tray Systems

NEMA VE 1 - Metal Cable Tray Systems